



Certificate of
constancy of performance
0063-CPR-222190013
Issue: 00



Issued	16-03-2023	Replaces	
First issued	16-03-2023	Page	1 / 2

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Product description:	DSPA Universal Activation System - Forwarder
Trademark:	DSPA
Type designation:	DSPA UAS-Forwarder
Hardware / Software:	Rev. A / N.A.
Conditions and essential characteristics:	See Annex 1
Variants:	See Annex 1

placed on the market under the name or trademark of:

Name of the manufacturer:	DSPA B.V.
Address:	Hulzenseweg 20
City:	6534 AN NIJMEGEN
Country:	NL

and produced in the manufacturing plant(s):

Manufacturing plant:	22646
Address:	-
City:	-
Country:	-

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-18:2005
EN 54-18:2005/AC:2007

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**

This certificate was first issued on 16-03-2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

Notified Body No. 0063



Remarks and observations

The following conditions are applicable:

Essential characteristics of EN 54-18:	Clauses:	Performance:
Response delay (response time)	5.2	Pass
Performance under fire conditions	5.1.4	Pass
Operational reliability	5.1.4	Pass
Durability of operational reliability: temperature resistance	5.3, 5.4	Pass
Durability of operational reliability; vibration resistance	5.8 to 5.11	Pass
Durability of operational reliability; humidity resistance	5.5, 5.6	Pass
Durability of operational reliability; corrosion resistance	5.7	Pass
Durability of operational reliability; electrical stability	5.2, 5.12	Pass

The product as described in this certificate includes the following type designations

- Product description:	DSPA Universal Activation System - Forwarder
- Trademark:	DSPA
- Type designation:	DSPA UAS-Forwarder
- Hardware version:	Rev. A
- Software version:	N.A.